

**Groundwater Sustainability Plan
Draft Regulations**

Via e-mail to: sgmps@water.ca.gov

Subject: Draft GSP Emergency Regulations Public Comment

DATE GROUNDWATER
SUSTAINABILITY PLAN
REGULATION COMMENT
RECEIVED BY DWR
2/22/2016

The City of Solvang has the following comments:

1. We recommend that all entities extracting/pumping over 2 acre-feet per year of groundwater from a basin should be required to have AWWA approved water meter(s) and annually report all groundwater extractions.
2. We recommend a minimum of 3 monitoring wells be required in a monitoring well network.

That concludes our comments at this time.

Respectfully,

Matt van der Linden, PE
Public Works Director/City Engineer
City of Solvang
411 Second Street
Solvang, CA 93463